

Fresno

253 Fulton St.
Fresno, CA 93721Ph: 559.650.1153
Fx: 559.650.1134**Quote****Customer ID**

002031

Attn

ANTHONY URIBE

Quote Date

3/5/2020

cc

Quote Number

RS-RQ18605

Job Number

RS-R24866

Customer InformationTHE CITY OF COALINGA
ATTN: ACCOUNTS PAYABLE
P.O. BOX 378
COALINGA, CA 93210**Ship To Information**THE CITY OF COALINGA
155 W. DURION AVENUE
COALINGA, CA 93210

Quote By: DAVE SCOTT

PO #: NEED PO

RFQ #:

Salesperson: BRIAN MATTA

Phone:

Fax:

Terms: Net 30

Nameplate Information

ID	RS-M15709
Motor-Make	US NIDEC
Rating	700
HP Unit	HP
RPM	1775

Frame	5012VP
Enclosure	WPI
Rated V.	4160
Rated A.	85

Quote Information**Reason Sent For Repair:** SERVICE CALL TO REMOVE 700HP (P15) MOTOR , BRING TO SHOP FOR REPAIR ESTIMATE. - - - CONTACT ANTHONY URIBE - 559-362-6567**Required Work:** TAKE APART & INSPECT - CLEAN ALL PARTS - CHECK ALL MECHANICAL FITS - BORE AND SLEEVE DRIVE END BEARING HOUSING - CORE TEST STATOR - REWIND STATOR - VPI WINDINGS - DYNAMIC BALANCE ROTOR - INSTALL NEW BEARINGS & V-RING - ASSEMBLE, TEST AND PAINT**Labor****Unit Price****Ext Price**

Total for Labor : 9,690.00

Material**Unit Price****Ext Price**

Total for Material : 12,591.02

Subtotal : 22,281.02

Tax : 1,004.13

Total for Quote RS-RQ18605 : 23,285.15

Quotes Do Not Include Sales Tax or Freight, Unless Otherwise Noted.
We Are not Responsible For Items Left Over 60 Days.
Quote is valid for 30 days.

SIGNATURE: _____

DATE: _____

PO# (IF NOT ALREADY ISSUED):

Ship Via: UPS

Page 1 of 1